

ANNEXURE - I

F-115

(Annexure to G.O.Ms.No.56, Home (ser.IV) Department, Dated:26.07.2019)

Instructions to be followed for schools existing before 13.04.2009:**SELF CERTIFICATION FORM****Self Certification of Fire Safety Measures by School Management:****i) General Information for School Building of all categories i.e., A, B, C & D.**

Sl. No.	Details	
1	Date of the opening of the school building	15.03.2000
2	Name of the applicant	MARKANDEYULU SURI
3	Name and address of the school	KENDRIYA VIDYALAYA SIDDIPET First Floor Ellenki Engineering College Campus, Near Rural Police Station, Chinnagundavelly, Siddipet District. Telangana. 502107.
4	Telephone Number and email of the applicant	9000347806, kvsiddipet@gmail.com
5	Height of the building (in meters)	14.90 Meters
6	No of floors	G+3 (Four Floors)
7	Abutting Road width (in meters)	12.00 Meters
8	Built-up area of each floor in Sq. Mtrs Stilt _____ Ground _____ Floor1 _____ Floor2 _____ Floor3 _____	1725.00 Sq. Mtrs. 1725.00 Sq. Mtrs. 1725.00 Sq. Mtrs. 650.00 Sq. Mtrs.
9	Number of Staircases Staircase 1 _____ (Width in meters) Staircase 2 _____ (Width in meters)	3.25 Meters 1.5 Meters
10	Width of each Staircase	3.25 Meters & 1.25 Meters
11	Open Spaces North _____ East _____ West _____ South _____	6.00 Meters 7.00 Meters 7.00 Meters 7.00 Meters

S. manandeyulu
26.02.2021

Signature with date of
School Authority and Seal

Principal
Kendriya Vidyalaya
Siddipet, Telangana

Chairman, VMC, KV SIDDIPET

District Collector & Magistrate Siddipet

CHAIRMAN
Vidya Management Committee
Kendriya Vidyalaya
SIDDIPET, T.S. INDIA.

Contd 2

B) School Buildings with Ground plus two floors and less than 15 Meters in height.

Sl. No.	Fire equipment required	Scale of fire equipment as per Norms	Required	Provided Yes/ NO
1	Fire Extinguishers (IS 2190:2010)	Two 09 litres water expelling extinguishers or ABC 4 kgs fire extinguishers, for every 200 square meters with minimum of 04 extinguishers per compartment/floor. The extinguisher should be so located as to be available within 15 meters radius.	31	YES
2	First Aid Hose Reel (IS 884:1985)	1 No for Every 1000 square meter	07	YES
3	Terrace Tank over respective tower terrace	10000 Litres (5000 Litres additionally shall be provided if basement exceeds 200 square meters)	25,000 Litres	YES
4	Automatic Sprinkler System (IS 15105:2002) The IS standard may be downloaded from www.https://bis.gov.in/	To be installed in basement. If area of basement exceeds 200 square meters	Not Applicable	YES
5	Pump capacity in LPM at the terrace tank level with minimum pressure of 3.5kg/ cm ²	450 LPM (450 LPM additionally shall be provided if basement exceeds 200 square meters)	900 LPM	YES
Additional Fire Safety Measures in lieu of deficiency in Setbacks.				
1	Water Shower curtain	Water Shower curtain shall be provided in all floors on the side/ sides having deficiency of setback to overcome exposure hazard from fires neighbouring property.	YES	YES
2	Fire Brigade inlet	02 Nos		

Note: If the floor area in a single floor more than 500 square meters and if there is only single stair case, a second stair case of 1.5 Meters width shall be provided with concrete/ metal steel structure.

Chairman, VMC, KV SIDDIPET

District Collector & Magistrate Siddipet

CHAIRMAN
Vidya Management Committee
Kendriya Vidyalaya
SIDDIPET, T.S. INDIA.

Signature with date of
School Authority and Seal

Principal
केंद्रीय विद्यालय
Kendriya Vidyalaya
सिद्धिपेट, तेलंगणा
Siddipet, Telangana


Conrd.....3

ii) General Fire Safety Measures which should be followed by all schools:-

Sl. No.	General Fire Safety Measures	Whether followed Yes/ No
1	The school building shall not be housed in temporary structures with roofs of tent cloth, thatched or any other combustible materials.	YES
2	It should be ensured that the available Fire Safety Equipment is always in good working condition	YES
3	Pre-School, kinder Garden and Class/Grade 1 Students shall be located on Ground Floor/level of Exit discharge and Class/Grade 2 Students shall be located not above One Floor higher than Ground Floor/level of Exit discharge	YES
4	Kitchen should be constructed/provided away from the school building	Not Applicable
5	All schools shall prepare an Evacuation Plan in consultation with local Fire Officer	YES
6	All Teachers/Employees should be trained in operating the available Fire Safety Equipment in the building	YES
7	All Exits/Escape routes shall be kept free from any obstructions for free passage in case of any emergency	YES
8	All the internal staircases, lifts, lobbies and corridors should be adequately ventilated and illuminated.	YES
9	If the school is provided with central Air-conditioning system, all safety measures as per Clause 10.1 of IS 14435:1997 should be followed.	Not Applicable
10	School Buildings shall be kept free from inflammable and toxic materials. If storage is inevitable, they should be stored safety.	YES
11	Any Hazardous/Combustible Material/ Volatile Flammable Liquids shall not be stored in School Buildings	YES
12	Dos and DONTs in case of any Fire/ Emergency shall be properly displayed at Strategic locations of the building.	YES
13	Auto Glow Sign Boards shall be provided indicating Exits/Escape Routes.	YES
14	Electric Wiring in the entire building shall be checked by the competent authority	YES
15	Structural Stability of the building shall be checked and certified by the competent authority	YES
16	Public Address System shall be provided for use in case of any emergency and this system shall cover the entire building,	YES
17	Detailed information regarding the number of students in each Room and the number of Students in each Class Room and the number of teachers/employees working shall be displayed at Strategic locations of the building.	YES

18	Display all Emergency supporting numbers such as nearest Fire Stations, Police Stations, Hospitals/ Ambulance etc. on all floors and at Strategic locations.	YES
19	A pictorial map with the details of Entries/Exits, details of Class Rooms/Laboratories/Staff Rooms and Open Place (Assembly Point) of the School Building shall be prepared and displayed in Strategic Locations.	YES
20	If Basement area of the building exceeds 200 square meters, required to provide Automatic Sprinkler as per IS 15105:2002	Not Applicable


We The Principal Kendriya Vidyalaya Siddipet School Management/Correspondent hereby certify that the information furnished is correct and if it is noticed at any time that the information provided is false, we understand that our school affiliation may be cancelled by the Concerned Authority. We have installed fire safety measures as per the Annexure I and undertake to maintain the same in good working condition at all times.



Signature with date of
School Authority and Seal

Name & Designation:

Principal
केंद्रीय विद्यालय
Kendriya Vidyalaya
सिद्धिपेट, तेलंगणा
Siddipet, Telangana.


CHAIRMAN VMC, KV SIDDIPET
District Collector & Magistrate, SIDDIPET (T.S)

CHAIRMAN
Vidya Management Committee
Kendriya Vidyalaya
SIDDIPET, T.S INDIA.

Copy to:

The Divisional Fire Officer of concerned District.



**GOVERNMENT OF TELANGANA
STATE DISASTER RESPONSE & FIRE SERVICES DEPARTMENT
FORM – 12**



(See Rule 26 (2))

File Rc.No. 10349/SFO/Siddipet/2021 Date : 04/01/2021

Notice For Violation Of Fire Prevention And Fire Safety Measures.

I, **A.Shravan, SFO-Siddipet** empowered by section 21 of Telangana Fire Service Act, 1999 and Rule 26 of Telangana Fire and Emergency Operations and Levy of Fee Rules, 2006 on the basis of inspection conducted by **A.Shravan, SFO-Siddipet**, Station dated. **04/01/2021** do hereby call upon you to undertake the following Fire Prevention and Fire Safety Measures in Building/Premises **KENDRIYA VIDYALAYA, SIDDIPET, H.NO. 7-26, ELLANKI ENGINEERING COLLEGE CAMPUS, CHINNA GUNDAVALLI VILLAGE, NEAR RURAL POLICE STATION, SIDDIPET**

2. Deficiencies in Mandatory Open Spaces all around the building:

Direction	Open Space Required as per Go.Ms.No.168 MA&UD (M) Dept.,Dt.07-04-2012.	Open space Provided	Deficit
North	6.00	6.00	0.00
East	7.00	7.00	0.00
West	7.00	7.00	0.00
South	7.00	7.00	0.00

3) Deficiencies in Means of Escape:

Floor type	Type of Occupancy	Buil-up Area in Sq.Mtrs	Occupant Load	Means of escape required as per table 21 of NBC	Means of escape provided	Deficit
Ground	EDUCATIONAL B-1 Schools up to senior secondary level	1725.00	431.00	4.31	4.75	0.00
1st Floor	EDUCATIONAL B-1 Schools up to senior secondary level	1725.00	431.00	4.31	4.75	0.00
2nd Floor	EDUCATIONAL B-1 Schools up to senior secondary level	1725.00	431.00	4.31	4.75	0.00
3rd Floor	EDUCATIONAL B-1 Schools up to senior secondary level	650.00	162.00	1.62	1.50	0.12
Total		5825.00				

4) Deficiencies in Fire Safety Measures:

Sno	Fire Fighting System.	Required As per NBC	Provide d	Defici t
1	Fire Extinguishers	31.00	6	25
2	First Aid Hose Reel	7.00	0	7
3	Wet Riser	0.00	0	0
4	Down Comer	2.00	0	2
5	Yard Hydrant	0.00	0	0
6	Automatic Sprinkler System	0.00	0	0
7	Manually Operated Electronic Fire Alarm Systems	7.00	0	7
8	Automatic Detection and Alarm System	0.00	0	0
9	Under-ground Static Water Storage Tank Combined Capacity for Wet Riser, Yard Hydrant and Sprinklers per Set of Pumps in Litres	0.00	0	0
10	Terrace Tank over Respective Tower Terrace in Litres	25000.00	25000	0
11	Pump Capacity in LPM at the Terrace Tank Level with Minimum Pressure of 3.5 kg/cm ²	900.00	0	900
12	Pump Near Underground Static Water Storage Tank (Fire Pump) with Minimum Pressure of 3.5 kg/cm ² at Remotest Location (Electrical)	0	0	0
13	Capacity of Electrical Pump in LPM	0.00	0	0

14	Pump Near Underground Static Water Storage Tank (Fire Pump) with Minimum Pressure of 3.5 kg/cm ² at Remotest Location (Diesel)	0	0	0
15	Capacity of Diesel Pump in LPM	0.00	0	0
16	Pump Near Underground Static Water Storage Tank (Fire Pump) with Minimum Pressure of 3.5 kg/cm ² at Remotest Location (Electrical/Jockey)	0	0	0
17	Capacity of Electrical (Jockey) Pump in LPM	0.00	0	0

6) You have violated the conditions of Fire Service and thereby endangering lives and property of the inmates and public in and around your premises.

7) Take notice hereby, that you are directed to undertake the above Fire Safety and Fire Prevention measures ensuring the safety within 30 days from the date of receipt of this notice, failing which, action will be initiated against you in the court of Law under Section 31 of Telangana Fire Services Act, 1999.

8) You are directed to acknowledge receipt of this notice on its duplicate.

[Signature]
 Station Fire Officer
 04/01/2021
Station Fire Officer
 Ashrayan SFO, Siddipet
 Fire Station, Siddipet.

Attended
[Signature]
 15/04/2021
 प्राचार्य/PRINCIPAL
 के.वी.सिद्धिपेट/KV SIDDIPET

1	Fire Alarm System	1	1	1
2	Fire Extinguishers	11	11	11
3	First Aid Box	1	1	1
4	Fire Alarm	1	1	1
5	Down Counter	1	1	1
6	Fire Alarm	1	1	1
7	Automatic Sprinkling System	1	1	1
8	Manually Operated Extinguishers (Fire Alarm System)	1	1	1
9	Automatic Extinguishers and Alarm System	1	1	1
10	Underground Static Water Storage Tank (Capacity for Water Tank)	1	1	1
11	Pressure and Capacity of Water Storage Tank (Capacity for Water Tank)	1	1	1
12	Pump Near Underground Static Water Storage Tank (Fire Pump) with Minimum Pressure of 3.5 kg/cm ² at Remotest Location (Diesel)	0	0	0
13	Capacity of Diesel Pump in LPM	0.00	0	0